

WSP Canada Inc.

ATTN: Marc St-Germain

100 Commerce Valley Drive West

Thornhill ON L3T 0A1

Date Received: 19-JUN-20

Report Date: 29-JUN-20 09:48 (MT)

Version: FINAL

Client Phone: 905-882-4211

Certificate of Analysis

Lab Work Order #: L2463738

Project P.O. #: 191-09337-01

Job Reference: 500015224

C of C Numbers: Legal Site Desc:

Candice Hunter Account Manager

 $[This\ report\ shall\ not\ be\ reproduced\ except\ in\ full\ without\ the\ written\ authority\ of\ the\ Laboratory.]$

ADDRESS: 95 West Beaver Creek Road, Unit 1, Richmond Hill, ON L4B 1H2 Canada | Phone: +1 905 881 9887 | Fax: +1 905 881 8062 ALS CANADA LTD | Part of the ALS Group | An ALS Limited Company





ANALYTICAL GUIDELINE REPORT

L2463738 CONTD....

Page 2 of 3

500015224		MALII	ICAL	סוט	LLIINL	KEPOK	. I	:	Page 2 29-JUN-20 0	
Sample Detai Grouping	ls Analyte	Result	Qualifier	D.L.	Units	Analyzed			ne Limits	
L2463738-1 Sampled By: Matrix:	PLUMBING		FFM-DF-S				#1	#2		
Total Metals Lead (Pb)		<1.0		1.0	ug/L	25-JUN-20	10			
L2463738-2 Sampled By: Matrix:	~P2 ST. FRANCIS DE SALES-50 M. CAKE on 18-JUN-20 @ 16:46 PLUMBING		FFM-DF-F				#1	#2		
Total Metals Lead (Pb)		<1.0		1.0	ug/L	25-JUN-20	10			

Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***					
PB-ONT-DW-243-WT	Water	Lead (O.Reg 243/07)	EPA 200.8					
TURB-MET-WT Water		Turbidity on preserved metals	APHA 2130 B					
			ered by the sample under defined conditions with the intensity of light scatter readings are obtained from a Nephelometer.					
		difications from specified reference	e methods to improve performance					
·	corporate mo	difications from specified reference	e methods to improve performance.					
** ALS test methods may inc	corporate mo	· · · · · · · · · · · · · · · · · · ·	e methods to improve performance. performed analytical analysis for that test. Refer to the list below:					
** ALS test methods may inc	corporate moss: above test c	· · · · · · · · · · · · · · · · · · ·	· · · · · · · · · · · · · · · · · · ·					

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg wwt - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

ONTARIO, CANADA

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to, fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guideline limits are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.



Quality Control Report

Workorder: L2463738 Report Date: 29-JUN-20 Page 1 of 2

Client: WSP Canada Inc.

100 Commerce Valley Drive West

Thornhill ON L3T 0A1

Contact: Marc St-Germain

Test		Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
PB-ONT-DW-243-WT		Water							
Batch	R5131861								
WG3348810 Lead (Pb)	-4 DUP		WG3348810-3 2.0	2.0		ug/L	0.6	20	25-JUN-20
WG3348810 Lead (Pb)	-2 LCS			91.6		%		70-130	25-JUN-20
WG3348810 Lead (Pb)	-1 MB			<1.0		ug/L		1	25-JUN-20
WG3348810 Lead (Pb)	-5 MS		WG3348810-3	90.7		%		70-130	25-JUN-20

Quality Control Report

Workorder: L2463738 Report Date: 29-JUN-20

Client: WSP Canada Inc. Page 2 of 2

100 Commerce Valley Drive West Thornhill ON L3T 0A1

Contact: Marc St-Germain

Legend:

Limit ALS Control Limit (Data Quality Objectives)

DUP Duplicate

RPD Relative Percent Difference

N/A Not Available

LCS Laboratory Control Sample SRM Standard Reference Material

MS Matrix Spike

MSD Matrix Spike Duplicate

ADE Average Desorption Efficiency

MB Method Blank

IRM Internal Reference Material
CRM Certified Reference Material
CCV Continuing Calibration Verification
CVS Calibration Verification Standard
LCSD Laboratory Control Sample Duplicate

Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against predetermined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.





L2463738-COFC

DRINKING WATER CHAIN OF CUSTOD

ARE THE SAMPLES SUBJECT TO REGULATION 243/07?

YES Circle One

NO

IF NO IS IT AVAILABLE FOR CONSUMPTION YES NO

Please place separate schools on a SEPARATE Chain of Custody

(ALS) **Environmental Division**

ALS-Waterloo, 60 Northland Road, Unit 1, Waterloo, Ontario N2V 2B8 Phone: 519-886-6910 Fax: 519-886-9047 Toll-Free 1-800-668-9878 WORKS LAB QUOTE Q63028 CONTACT NAME FOR LAB USE ONLY ANALYSES REQUESTED PROJECT (91-09-331-0) Durham Catholic District School Board Scott Grieve Please indicate test for each sample by Checkmark in the box below SCHOOL NAME / ADDRESS CONTACT PHONE/FAX /EMAIL SUBMISSION NO. Scott.grieve@dcdsb.ca St. Francis de Sales, 72 Churchs St. S marc.st.germain@wsp.com daniel.buck@wsp.com RECEIVED MOE DWIS REGISTRATION# LOCAL PUBLIC HEALTH UNIT 5000 15 224 Region of Durham Public Health Co-Locate Facility: NAME/DWIS# HEALTH UNIT CONTACT PHONE/FAX attach): WORKS CATEGORY School Private School Tel: 905-668-7711 Nurserv 🗆 Fax: 905-666-6214 Ont DW Lead Other (specify or Check if NOT ok TEMPERATURE AT Check SAMPLE DESCRIPTION - Please provide information Volume 1L Plumbing Sample to completely identify the sample location (e.g. **Point** Sampling Date/Time School Name, Room #, etc), This description will PH <2 Time (appear on the Report. Date Time LAB ID Please indicate ONE Stand Time STANDING TAP/ OTHER (hh:mm) Time-period Plumbing not in use 500015124-HOFFH-DF-S 18/6/2020 01-Flush Time **FLUSHED** TAP/ OTHER (hh:mm) Length of Flushing Time 18/6/2020 4500015224-HOEFM-DY-SMI わた RESAMPLE YES | NOve Please ensure bottle is labelled similarly SAMPLED BY (print): Other Comments/Cautions (Please identify known or suspected hazards) / Reference Info (P.O. #, Proj #) Contact Number Please invoice to marc.st.germain@wsp.com 437-213-4850 DATE

> WT-FM-0275f v05 Reg 243/07 CoC Date: 28-Feb-15