



WSP Canada Inc.  
ATTN: Marc St-Germain  
100 Commerce Valley Drive West  
Thornhill ON L3T 0A1

Date Received: 19-JUN-20  
Report Date: 29-JUN-20 10:25 (MT)  
Version: FINAL

Client Phone: 905-882-4211

## Certificate of Analysis

Lab Work Order #: L2463822  
Project P.O. #: 191-09337-01  
Job Reference: 500316031  
C of C Numbers:  
Legal Site Desc:

Candice Hunter  
Account Manager

[This report shall not be reproduced except in full without the written authority of the Laboratory.]

ADDRESS: 95 West Beaver Creek Road, Unit 1, Richmond Hill, ON L4B 1H2 Canada | Phone: +1 905 881 9887 | Fax: +1 905 881 8062  
ALS CANADA LTD Part of the ALS Group An ALS Limited Company



# ANALYTICAL GUIDELINE REPORT

L2463822 CONTD....

Page 2 of 3

29-JUN-20 10:25 (MT)

500316031

Sample Details Grouping	Analyte	Result	Qualifier	D.L.	Units	Analyzed	Guideline Limits			
L2463822-1	~P1 ST. JOSEPHINE BAKHITA-500316031-H120-BFF-S									
Sampled By:	D. BUCK on 17-JUN-20 @ 16:04						#1	#2		
Matrix:	PLUMBING									
<b>Total Metals</b>										
Lead (Pb)		<1.0		1.0	ug/L	29-JUN-20	10			
L2463822-2	~P2 ST. JOSEPHINE BAKHITA-500316031-H120-BFF-F									
Sampled By:	D. BUCK on 17-JUN-20 @ 16:39						#1	#2		
Matrix:	PLUMBING									
<b>Total Metals</b>										
Lead (Pb)		<1.0		1.0	ug/L	29-JUN-20	10			

\*\* Detection Limit for result exceeds Guideline Limit. Assessment against Guideline Limit cannot be made.

\* Analytical result for this parameter exceeds Guideline Limit listed on this report. Guideline Limits applied:

**Ontario Drinking Water Regulation (ODWQS) JAN.1,2020 = [Suite] - ON-DW-STANDARD+GUIDELINES**

#1: Schedule 1 (Microbiological) and 2 (Chemical) Standards (JAN,2020)

#2: Ontario DW Aesthetic and Operational Guidelines (June, 2006)

Reference Information

Methods Listed (if applicable):

ALS Test Code	Matrix	Test Description	Method Reference***
PB-ONT-DW-243-WT	Water	Lead (O.Reg 243/07)	EPA 200.8
TURB-MET-WT	Water	Turbidity on preserved metals sample	APHA 2130 B
Sample result is based on a comparison of the intensity of the light scattered by the sample under defined conditions with the intensity of light scattered by a standard reference suspension under the same conditions. Sample readings are obtained from a Nephelometer.			

\*\*\* ALS test methods may incorporate modifications from specified reference methods to improve performance.

Chain of Custody numbers:

The last two letters of the above test code(s) indicate the laboratory that performed analytical analysis for that test. Refer to the list below:

Laboratory Definition Code	Laboratory Location	Laboratory Definition Code	Laboratory Location
WT	ALS ENVIRONMENTAL - WATERLOO, ONTARIO, CANADA		

GLOSSARY OF REPORT TERMS

Surrogates are compounds that are similar in behaviour to target analyte(s), but that do not normally occur in environmental samples. For applicable tests, surrogates are added to samples prior to analysis as a check on recovery. In reports that display the D.L. column, laboratory objectives for surrogates are listed there.

mg/kg - milligrams per kilogram based on dry weight of sample

mg/kg ww - milligrams per kilogram based on wet weight of sample

mg/kg lwt - milligrams per kilogram based on lipid-adjusted weight

mg/L - unit of concentration based on volume, parts per million.

< - Less than.

D.L. - The reporting limit.

N/A - Result not available. Refer to qualifier code and definition for explanation.

Test results reported relate only to the samples as received by the laboratory.

UNLESS OTHERWISE STATED, ALL SAMPLES WERE RECEIVED IN ACCEPTABLE CONDITION.

Analytical results in unsigned test reports with the DRAFT watermark are subject to change, pending final QC review.

Application of guidelines is provided "as is" without warranty of any kind, either expressed or implied, including, but not limited to, fitness for a particular purpose, or non-infringement. ALS assumes no responsibility for errors or omissions in the information. Guideline limits are not adjusted for the hardness, pH or temperature of the sample (the most conservative values are used). Measurement uncertainty is not applied to test results prior to comparison with specified criteria values.



## Quality Control Report

Workorder: L2463822

Report Date: 29-JUN-20

Page 1 of 2

Client: WSP Canada Inc.  
100 Commerce Valley Drive West  
Thornhill ON L3T 0A1  
Contact: Marc St-Germain

Test	Matrix	Reference	Result	Qualifier	Units	RPD	Limit	Analyzed
PB-ONT-DW-243-WT		Water						
Batch R5135631								
WG3350852-4	DUP	WG3350852-3						
Lead (Pb)		<1.0	<1.0	RPD-NA	ug/L	N/A	20	29-JUN-20
WG3350852-2	LCS		96.1		%		70-130	29-JUN-20
Lead (Pb)								
WG3350852-1	MB		<1.0		ug/L		1	29-JUN-20
Lead (Pb)								
WG3350852-5	MS	WG3350852-3	87.2		%		70-130	29-JUN-20
Lead (Pb)								

# Quality Control Report

Workorder: L2463822

Report Date: 29-JUN-20

Client: WSP Canada Inc.  
100 Commerce Valley Drive West  
Thornhill ON L3T 0A1  
Contact: Marc St-Germain

Page 2 of 2

## Legend:

---

Limit	ALS Control Limit (Data Quality Objectives)
DUP	Duplicate
RPD	Relative Percent Difference
N/A	Not Available
LCS	Laboratory Control Sample
SRM	Standard Reference Material
MS	Matrix Spike
MSD	Matrix Spike Duplicate
ADE	Average Desorption Efficiency
MB	Method Blank
IRM	Internal Reference Material
CRM	Certified Reference Material
CCV	Continuing Calibration Verification
CVS	Calibration Verification Standard
LCSD	Laboratory Control Sample Duplicate

## Sample Parameter Qualifier Definitions:

---

Qualifier	Description
RPD-NA	Relative Percent Difference Not Available due to result(s) being less than detection limit.

---

## Hold Time Exceedances:

All test results reported with this submission were conducted within ALS recommended hold times.

ALS recommended hold times may vary by province. They are assigned to meet known provincial and/or federal government requirements. In the absence of regulatory hold times, ALS establishes recommendations based on guidelines published by the US EPA, APHA Standard Methods, or Environment Canada (where available). For more information, please contact ALS.

---

The ALS Quality Control Report is provided to ALS clients upon request. ALS includes comprehensive QC checks with every analysis to ensure our high standards of quality are met. Each QC result has a known or expected target value, which is compared against pre-determined data quality objectives to provide confidence in the accuracy of associated test results.

Please note that this report may contain QC results from anonymous Sample Duplicates and Matrix Spikes that do not originate from this Work Order.

## Environmental Division

ALS-Waterloo, 60 Northland Road, Unit 1, Waterloo, Ontario N2V 2B8  
Phone: 519-886-6910 Fax: 519-886-9047 Toll-Free 1-800-668-9878

## DRINKING WATER CHAIN OF CUSTODY

**ARE THE SAMPLES SUBJECT TO REGULATION 243/07?**

**YES      Circle One      NO**

IF NO IS IT AVAILABLE FOR CONSUMPTION YES NO

Please place separate schools on a SEPARATE Chain of Custody

WORKS		LAB QUOTE Q63028		CONTACT NAME		ANALYSES REQUESTED												FOR LAB USE ONLY	
Durham Catholic District School Board		PROJECT		CONTACT PHONE/FAX/EMAIL		Please indicate test for each sample by Checkmark in the box below												SUBMISSION NO.	
SCHOOL NAME / ADDRESS		WORKS CATEGORY		HEALTH UNIT CONTACT PHONE/FAX		Ont DW Lead												RECEIVED BY:	
St. Josephine Bukhita		SI Williams		Tel: 905-668-7711														DATE/TIME:	
500316 031		Dr. E		Fax: 905-666-6214														9-00	
MOE DWIS REGISTRATION#		LOCAL PUBLIC HEALTH UNIT		HEALTH UNIT CONTACT PHONE/FAX		Other (specify or attach):												TEMPERATURE AT RECEIPT:	
500316 031		Region of Durham Public Health		Tel: 905-668-7711														24.2	
Co-Locate Facility: NAME/DWIS#		Nursery		Fax: 905-666-6214															
ccc present 500316 031		School Private School Nursery				Check if NOT ok												LAB ID	
St. Josephine Bukhita ccc																			
SAMPLE DESCRIPTION - Please provide information to completely identify the sample location (e.g. School Name, Room #, etc). This description will appear on the Report.		Plumbing Sample Point		Sampling Date/Time		pH <2													
		Please indicate ONE		Date Time															
STANDING		Stand Time (hh:mm)		TAP/ OTHER		Volume 1L													
Time-period Plumbing not in use																			
500316 031 - H120 BFF-S		6:15		DF															
FLUSHED		Flush Time (hh:mm)		TAP/ OTHER		Time Check													
Length of Flushing Time																			
500316 031 - H120 BFF-S		5 min.		DF															
RESAMPLE YES NO		Please ensure bottle is labelled similarly		Contact Number		Other Comments/Cautions (Please identify known or suspected hazards) / Reference Info (P.O. #, Proj #)													
Dawn Buck				437-213-4850															
SUBMITTED TO LAB BY: (SIGNATURE)		DATE																	
Dawn Buck		Jun 18/20				Please invoice to marc.st.germain@wsp.com													